



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2045445
Permit # 00040-2023UPG
Request Rec'd 01/11/2023
Amended Date
Approval Date 1/11/2023 DS
Permit Expires 7/11/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Thorntons LLC 2600 James Thornton Way Louisville, KY 40245 Contact: Maggie Seaugh (502) 425-8022	(2) FACILITY - name and address where tanks are located: Thorntons Inc #314 601 Rt 83 Bensenville, IL 60106 Contact: Neal Bhatt 6307660602
---	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 5) - 30,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 5) Piping - Shear Valves*

(d) *Product to be stored in each tank: (TK # 5) - Diesel Fuel*

(e) *Type of leak detection being used:*

Tank:

Piping:

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Replacing the shear valve on Master #22.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Beacon SSI, Inc.
10526 W. Cermak Rd Suite 302
Westchester, IL 60154

Contact Person: Patrick Ferriter
Phone: (708) 917-2263
Contractor Registration # IL002336 Exp. 1/27/2023

Sincerely,

Daniel G. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File