



City of Chicago  
Department of Public Health  
333 South State Street, Room 200  
Chicago, IL 60604  
3127453162

## Amended

### FOR OFFICE USE ONLY

Facility # 2017222  
Permit # 01100-2022UPG  
Request Rec'd 10/04/2022  
Amended Date 01/16/2023 Chi  
Approval Date 10/5/2022  
Permit Expires 4/5/2023

### Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  AZ SPE, LLC 12345 S. Keeler Ave. Alsip, IL 60803  Contact: Ahmad Zahdan (708) 372-7632	<b>(2) FACILITY</b> - name and address where tanks are located:  Amstar 4701 S. Western Blvd. Chicago, IL 60609  Contact: Khader Zahdan (708) 372-6732
---	--

### **(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 5) - 6,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 5) Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000L , (TK # 5) Piping - Other Steel Riser, (TK # 5) Piping - Other Submersible Pump, (TK # 5) Piping - Ball Valves , (TK # 5) Piping - Shear Valves , (TK # 5) Piping - Flex Connector Steel, (TK # 5) Piping - Single Wall STP/Tanktop Sump*
- (d) *Product to be stored in each tank: (TK # 5) - Gasoline - Premium*
- (e) *Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) *Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices: (TK # 5) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

### **(5) SPECIAL CONTINGENCIES :**


Amendment Reason: Dipsenser number for E85 was changed to #5/6 only.

### **(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

B & K Equipment Company  
2939 175th Street  
Lansing, IL 60438

Contact Person: Ed Angell  
Phone: (708) 474-3344  
Contractor Registration # IL1207 Exp. 2/14/2024

Sincerely,

A handwritten signature in black ink that reads "Seán Keane". The signature is written in a cursive style with a horizontal line underneath the name.

Raul Valdivia

cc: Storage Tank Safety Specialist  
Division File