



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 6041722
Permit # 00073-2023REM
Request Rec'd 01/19/2023
Amended Date
Approval Date 1/19/2023 DS
Permit Expires 7/19/2023

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Mac's Convenience Stores, LLC 1100 Situs Court, Suite 100 Raleigh, NC 27606</p> <p>Contact: Elizabeth Patterson (984) 389-1765</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Circle K #1359 536 Edwardsville Road Troy, IL 62294</p> <p>Contact: Steve Dickerson (812) 379-9227</p>
---	---

(3) REMOVAL OF PIPING:

- (a) Description/location of piping being removed:*
- (b) Which tank(s) are associated with the piping being removed: (TK # 1) - 20,000, (TK # 2, 3) - 10,000*
- (c) Reason of piping being removed:*
- (d) If piping is leaking, indicate IEMA incident number:*

- (4)** After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

- (5) SPECIAL CONTINGENCIES** : 2. Shut down the power to each of the six (6) Encore 700S dispensers. Disconnect the electric and product piping.
3. Remove each dispenser and set aside in a secure location.
 4. Blow the fuel back to the underground storage tanks.
 5. Saw cut and demo approximately a 14' x 12' area around each of the six (6) dispenser sumps. Canopy bases will be exposed when existing islands are demoed. Neumayer assumes that all bases are, structurally, in good condition, and will not be compromised when exposed. If canopy bases are not in good condition, and require support brackets to be installed, the additional cost of equipment and labor to install brackets will be billed via Change Order.
 6. Disconnect the electric and product piping from the STPs. Remove all three (3) STPs and properly dispose.
 7. Remove the Diesel and Premium ATG probes and save for reuse. Remove the Diesel overfill prevention valve and save for reuse.
 8. Saw cut and demo the existing tank pad around the NL STP, Diesel STP, Diesel ATG, Diesel vapor, Diesel spill container, Premium STP, Premium ATG and Interstice. Excavate down to expose the tank tops.
 9. Load and dispose the concrete, manholes, STP sumps, dispenser sumps and u-shaped bumpers and properly dispose.
 10. Pull the existing product piping through the existing chase pipe and properly dispose.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc.
5060 Arsenal Street
St. Louis, MO 63139

Contact Person: Jimmy Spiros
Phone: (314) 772-4501
Contractor Registration # IL1502 Exp. 3/26/2024

Sincerely,

Daniel Starks

Division File