



Office of the Illinois State Fire Marshal
 Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 2177851020

FOR OFFICE USE ONLY
 Facility # 5040225
 Permit # 00069-2023UPG
 Request Rec'd 01/17/2023
 Amended Date 01/19/2023 DS
 Approval Date 1/18/2023 DS
 Permit Expires 7/18/2023

Amended

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Pilot Travel Centers, LLC 5508 Lonas Rd. Knoxville, TN 37909</p> <p>Contact: Joey Cupp (865) 588-7488</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Mr. Fuel #1245 4th Corvette Drive Litchfield, IL 62056</p> <p>Contact: Joey Cupp (865) 588-7488</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1, 2) - 15,000, (TK # 7) - 20,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1, 2, 7) Piping - Shear Valves*
- (d) *Product to be stored in each tank: (TK # 1, 2) - Diesel Fuel, (TK # 7) - B-99*
- (e) *Type of leak detection being used:*
 Tank:
 Piping:
- (f) *Corrosion Protection being used:*
 Tank:
 Piping:
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

THE EXSISTING SHEAR VALVE IS NOT HOLDIGN WHEN CLOSED. WILL CHANGE SATELLITE SHEAR VALVE ON #18. THIS IS UNDER #18 DISPENSER AND IS DIESEL SATELLITE FROM #17

CHANGE SHEAR VALVE UNDER DISPENSER 19


Amendment Reason: change shear valve under 19 dispenser

<p>(6) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u></p> <p>Neumayer Equipment Company, Inc.</p>	<p>Contact Person: Jimmy Spiros</p>
---	-------------------------------------

5060 Arsenal Street
St. Louis, MO 63139

Phone: (314) 772-4501
Contractor Registration # IL1502 Exp. 3/26/2024

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in black ink and is positioned above a thin horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File