



Office of the Illinois State Fire Marshal
 Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 2177851020

FOR OFFICE USE ONLY
 Facility # 2010057
 Permit # 00111-2023UPG
 Request Rec'd 01/31/2023
 Amended Date
 Approval Date 1/31/2023 DS
 Permit Expires 8/1/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Crete 2, LLC 23802 Volbrecht Road Crete, IL 60417</p> <p>Contact: Alex Singh (219) 775-0313</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Crete 2, LLC 1351 Main Street Crete, IL 60417</p> <p>Contact: Nasir Yaqoob (219) 775-0313</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 5, 6) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 5, 6) Piping - Flexible Double Wall A.P.T. Poly Tech S150SC from existing tanks to dispensers as shown in site plan, (TK # 5, 6) Piping - Other Submersible Pump, (TK # 5, 6) Piping - Ball Valves , (TK # 5, 6) Piping - Shear Valves , (TK # 5, 6) Piping - Single Wall STP/Tanktop Sump*
- (d) Product to be stored in each tank: (TK # 5, 6) - Gasoline*
- (e) Type of leak detection being used:*
 - Tank: (TK # 5, 6) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD , (TK # 5, 6) Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors*
 - Piping: (TK # 5, 6) Leak Detect - Piping - Electronic Pressurized Line Leak Detection, (TK # 5, 6) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown in all submersible and dispenser sumps*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices: (TK # 5, 6) Spill Contain Device - Single Wall Spill Bucket*
- (h) Overfill prevention devices: (TK # 5, 6) Overfill Prev Device - Overfill Alarm*
- (i) Manway accessible at grade:*


(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Replaced piping exceeds 20 feet or 50% of the total pipe run. Upgrading tanks 5&6 with new containment, double-wall piping, new leak detection system as part of a full site rebuild. Installing single wall dispenser sumps under each dispenser.

(6) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u>	
B & K Equipment Company 2939 175th Street	Contact Person: Ed Angell Phone: (708) 474-3344

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File