



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 5040225  
Permit # 00121-2023REM  
Request Rec'd 02/02/2023  
Amended Date  
Approval Date 2/2/2023 DS  
Permit Expires 8/2/2023

**Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.**

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Pilot Travel Centers, LLC 5508 Lonas Rd. Knoxville, TN 37909</p> <p>Contact: Joey Cupp (865) 588-7488</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Mr. Fuel #1245 4th Corvette Drive Litchfield, IL 62056</p> <p>Contact: Joey Cupp (865) 588-7488</p>
---	---

**(3) REMOVAL OF PIPING:**

- (a) Description/location of piping being removed:*
- (b) Which tank(s) are associated with the piping being removed: (TK # 1, 2) - 15,000*
- (c) Reason of piping being removed:*
- (d) If piping is leaking, indicate IEMA incident number:*

(4) After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

- (5) **SPECIAL CONTINGENCIES** : 2. Remove the dispensers from the island and set aside for re-installation. NOTE: Def piping is overhead and enters the sideskin of the dispensers.
- 3. Blow the fuel out of the lines back into the tanks.
  - 4. Saw cut and demo around both of the diesel STP's and the Bio STP. Use a vac truck to remove the backfill material at the STP's so that they are completely exposed. Backfill material will be stored on site for re-use.
  - 5. Saw cut and demo to the Bio shed and from the shed to the 1st island.
  - 6. At the islands, we will saw cut and demo a 5' path right thru the center of the islands. The island bumper ends will remain.
  - 7. Saw cut an electric trench from the side of the store to the tank hole.
  - 8. Remove the existing APT piping and UDC's

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Neumayer Equipment Company, Inc.  
5060 Arsenal Street  
St. Louis, MO 63139

Contact Person: Jimmy Spiros  
Phone: (314) 772-4501  
Contractor Registration # IL1502 Exp. 3/26/2024

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File