



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**Extended**

**FOR OFFICE USE ONLY**

Facility # 2010685  
Permit # 00886-2022UPG  
Request Rec'd 08/13/2022  
Amended Date  
Approval Date 8/15/2022 DS  
Permit Expires 8/15/2023

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Graham C-Stores Co. 39109 N. US Hwy 41 Wadsworth, IL 60083  Contact: John Graham (847) 223-3710	<b>(2) FACILITY</b> - name and address where tanks are located:  Lake Zurich #3 1 N. Rand Road Lake Zurich, IL 60047  Contact: Lisa Railton (847) 223-3710
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 1) - 8,000, (TK # 2, 3) - 6,000, (TK # 6) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1, 2, 3, 6) Piping - Flexible Double Wall NUPI Smartflex*
- (d) Product to be stored in each tank: (TK # 1, 2) - Gasoline - Regular, (TK # 3) - Diesel Fuel, (TK # 6) - Gasoline - Premium*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping: (TK # 1, 2, 3, 6) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices: (TK # 1, 2, 3, 6) Overfill Prev Device - Overfill Alarm*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

Existing tanks and canopy are to remain. Existing islands are to be replaced with new dispenser containment sumps. Existing STP sumps, ATG's, Spill / Overfill are to remain.

Replacing the existing DWFRP piping w/ NUPI DW Semi-Rigid. Installing new dispenser sumps with VR liquid sensors. Installing VR Overfill Alarm. Replacing the existing vent piping w/ Nupi SW Semi-Rigid to new 2" Stainless risers at vent rack.

Replaced piping exceeds 20 feet or 50% of the total pipe run.

**NOTE: A removal permit must be obtained for the existing piping that is being removed**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Performance Tank, Inc.  
730 Creel Drive  
Wood Dale, IL 60191

Contact Person: Tim Berg  
Phone: (630) 860-9500  
Contractor Registration # IL881 Exp. 12/8/2022

Sincerely,



---

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File