



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2030020
Permit # 00169-2023UPG
Request Rec'd 02/16/2023
Amended Date
Approval Date 2/16/2023 DS
Permit Expires 8/16/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Skipper Buds of Illinois, Inc. 215 Northpoint Dr PO Box 369 Winthrop Harbor, IL 60096</p> <p>Contact: Rashleger Robert (708) 872-3200</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Skipper Buds Of Illinois, Inc. 215 Northpoint Dr PO Box 369 Winthrop Harbor, IL 60096</p> <p>Contact: Scott Benser (847) 872-0292</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3) - 12,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1, 2, 3) Piping - Flexible Double Wall OPW Flexworks , (TK # 1, 2, 3) Piping - Ball Valves , (TK # 1, 2, 3) Piping - Aboveground , (TK # 1, 2, 3) Piping - Single Wall Transition Sump*
- (d) *Product to be stored in each tank: (TK # 1, 2) - Gasoline - Premium, (TK # 3) - Diesel Fuel*
- (e) *Type of leak detection being used:*
- Tank: (TK # 1, 2, 3) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD*
- Piping: (TK # 1, 2, 3) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown in transition sump and all dispenser sumps*
- (f) *Corrosion Protection being used:*
- Tank:*
- Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Replaced pipiWe will be replacing all of the singlewall steel piping that runs from the existing underground piping located where dock starts, install transition sump on land and run new OPW 2" Flexworks doublewall from transition sump under dock planks to existing dispenser sumps. We will install under dock planks (3) singlgewall poly OPW sumps due to the Owner removes these dock in the winter time in three sections. We will upgrade tank monitoring system with new Veeder Root TLS-450 Plus with new tank probes and non discriminating sump sensors in all sumps.

piping exceeds 20 feet or 50% of the total pipe run.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Stenstrom Petroleum Services Group
2422 Center Street
Rockford, IL 61108

Contact Person: Robert Stenstrom
Phone: (815) 398-6250
Contractor Registration # IL1890 Exp. 4/12/2024

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File