



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2034084
Permit # 00180-2023UPG
Request Rec'd 02/18/2023
Amended Date
Approval Date 2/21/2023 DS
Permit Expires 8/22/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Graham Enterprise, Inc. 750 Bunker Court Vernon Hills, IL 60061 Contact: John Graham (847) 837-0777	(2) FACILITY - name and address where tanks are located: Lake Street BP @ 83 (GEI-160) 1275 North US Route 83 Grayslake, IL 60060 Contact: Lorraine Pempek (847) 548-0064
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3) - 12,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1, 2, 3) Piping - Flexible Double Wall NUPI Smartflex , (TK # 1, 2, 3) Piping - Other Submersible Pump, (TK # 1, 2, 3) Piping - Shear Valves , (TK # 1, 2, 3) Piping - Single Wall STP/Tanktop Sump*
- (d) *Product to be stored in each tank: (TK # 1) - Gasoline - Regular, (TK # 2) - Diesel Fuel, (TK # 3) - Gasoline - Premium*
- (e) *Type of leak detection being used:*

Tank:

Piping: (TK # 1, 2, 3) Leak Detect - Piping - Electronic Pressurized Line Leak Detection, (TK # 1, 2, 3) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown in all submersible and dispenser sumps
- (f) *Corrosion Protection being used:*

Tank:

Piping:
- (g) *Spill containment devices, piping, and dispenser containment devices: (TK # 1, 2, 3) Spill Contain Device - Single Wall Spill Bucket*
- (h) *Overfill prevention devices: (TK # 1, 2, 3) Overfill Prev Device - Overfill Drop Tube Valve , (TK # 1, 2, 3) Overfill Prev Device - Overfill Alarm*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Installing new DW Nupi semi-rigid product piping from new STP's inside the existing STP sumps to (4) new dispenser islands w/ new Nupi dispenser sumps under the existing canopy. Installing new DW Nupi remote fill piping from the existing "fill sumps" to new Defender SW spill buckets at parkway as shown on plan. Installing new Nupi SW vent / stage I piping to vent rack in parkway area as shown on plans. Installing VR Overfill alarm, Defender Overfill Valves, VR 323 sensors at all sumps, new VR PLLDs at new FE Petro STP's. Existing tanks are to remain. Existing VR TLS 350 is to remain.

Replaced piping exceeds 20 feet or 50% of the total pipe run.


NOTE: After May 1, 2003, any new installation with a remote fill over 20 feet in length shall have interstitial monitoring and an audible and visible overfill alarm. Remote fills shall be sloped back to the tank.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Performance Tank, Inc.
730 Creel Drive
Wood Dale, IL 60191

Contact Person: Tim Berg
Phone: (630) 860-9500
Contractor Registration # IL881 Exp. 12/8/2024

Sincerely,

A handwritten signature in cursive script, reading "Daniel G. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File