



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2014721
Permit # 00183-2023UPG
Request Rec'd 02/17/2023
Amended Date
Approval Date 2/21/2023 DS
Permit Expires 8/22/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>AZ SPE, LLC 12345 S. Keeler Ave. Alsip, IL 60803</p> <p>Contact: Ahmad Zahdan (708) 372-7632</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Elmwood Park Phillips 66 7750 West Grand Avenue Elmwood Park, IL 60635</p> <p>Contact: Haytham Albusalah (847) 361-7274</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 3) - 4,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 3) Piping - Flexible Double Wall A.P.T. Poly Tech S150SC , (TK # 3) Piping - Flex Connector Steel*
- (d) *Product to be stored in each tank: (TK # 3) - E-85*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

The double walled rigid fiberglass E85 product line has failed a line test. The leak is not in either the dispenser or pump sumps. It is in the buried portion of the line and would be extremely difficult to find. The entire underground line will be replaced with flexible double walled pipe. The line only runs from the pump sump to one dispenser sump.

Replaced piping exceeds 20 feet or 50% of the total pipe run.

NOTE: Site has existing sensors

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:


B & K Equipment Company

Contact Person: Ed Angell

2939 175th Street
Lansing, IL 60438

Phone: (708) 474-3344
Contractor Registration # IL1207 Exp. 2/14/2024

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File