



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 4017906
Permit # 00191-2023UPG
Request Rec'd 02/22/2023
Amended Date
Approval Date 2/22/2023 DS
Permit Expires 8/22/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Grant & Grant Investment LTD 101 West Division Street Findlay, IL 62534 Contact: Christina Grant (217) 756-3143	(2) FACILITY - name and address where tanks are located: R & K One Stop, Inc. 101 West Division Findlay, IL 62534 Contact: Christina Grant (217) 756-3154
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 6) - 2,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 6) Piping - Flexible Double Wall OPW Flexworks , (TK # 6) Piping - Shear Valves , (TK # 6) Piping - Flex Connector Steel, (TK # 6) Piping - Double Wall STP/Tanktop Sump*
- (d) *Product to be stored in each tank: (TK # 6) - Diesel Fuel*
- (e) *Type of leak detection being used:*
 - Tank: (TK # 6) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 300*
 - Piping: (TK # 6) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection, (TK # 6) Leak Detect - Piping - Discriminating Sump Sensor*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices: (TK # 6) Spill Contain Device - Double Wall Spill Bucket*
- (h) *Overfill prevention devices: (TK # 6) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Existing canopy to remain. Installation of new island to accomodate dispenser sumps, sensors and flexible piping with new tank installation completed. We will add the STP , DW overspill, DW flexible piping and tank/stp sump to complete connections to new islands from new tank installation

Replaced piping exceeds 20 feet or 50% of the total pipe run.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:


Bolin Enterprises, Inc.

Contact Person: Scott Justice

506 North East 15th Street PO Box 70
Casey, IL 62420

Phone: (217) 932-4533
Contractor Registration # IL002333 Exp. 10/10/2024

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File