



City of Chicago
Department of Public Health
 333 South State Street, Room 200
 Chicago, IL 60604
 3127453162

Amended

FOR OFFICE USE ONLY
 Facility # 2020721
 Permit # 00099-2023UPG
 Request Rec'd 01/27/2023
 Amended Date 02/23/2023 Chi
 Approval Date 1/27/2023
 Permit Expires 7/27/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Chicago Transit Authority 567 W. Lake St Chicago, IL 60661</p> <p>Contact: Shile Liang (312) 681-2747</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>CTA Forest Glen Bus Facility 5419 West Armstrong Chicago, IL 60646</p> <p>Contact: Symone Amos (773) 774-2666</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 5, 6, 7, 8) - 20,000, (TK # 9) - 4,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 5, 6, 7, 8, 9) Piping - Steel Single Wall Piping*
- (d) Product to be stored in each tank: (TK # 5, 6, 7, 8) - Diesel Fuel, (TK # 9) - Used Oil*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Amendment Reason: Tank #11 has doublewall piping with gravity feed

(6) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u>	
Protanic 658 North Progress Drive PO Box 80265 Saukville, WI 53080	Contact Person: Kylie Krombach Phone: (262) 268-1150 Contractor Registration # IL1413 Exp. 9/26/2024

Sincerely,

Seán Keane

Raul Valdivia

cc: Storage Tank Safety Specialist
Division File