



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 7031802
Permit # 00242-2023REM
Request Rec'd 03/06/2023
Amended Date
Approval Date 3/6/2023 DS
Permit Expires 9/6/2023

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Mac's Convenience Stores, LLC 1100 Situs Court, Suite 100 Raleigh, NC 27606</p> <p>Contact: Elizabeth Patterson (984) 389-1765</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Circle K #4700145 100 Potomac Blvd. Mount Vernon, IL 62864</p> <p>Contact: Elizabeth Patterson (984) 389-1765</p>
---	--

(3) REMOVAL OF TANKS:

- (a) Number and size of tanks being removed: (TK # 5, 7) - 8,000, (TK # 6) - 12,000*
- (b) Description/location of piping being removed:*
- (c) Product to be stored in each tank: (TK # 5) - B-11, (TK # 6) - Gasoline - Regular, (TK # 7) - Gasoline - Premium*
- (d) Reason of tanks being removed:*
- (e) If tank(s) is leaking, indicate IEMA incident number:*
- (f) Date each tank was last used: (TK # 5, 6, 7) - Unknown*

- (4)** The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.


- (5) SPECIAL CONTINGENCIES** : 2. Remove three (3) Submerged Turbine Pumps (STP) and properly dispose of each.
3. Disconnect the electric, drain and plug product inlets and remove dispensers from islands. Set dispensers aside on site for reinstallation.
4. Saw cut and demo approximately 15' wide and 43' long opening to expose three (3) existing STP sumps. On the premium and diesel tank, the probe and spill buckets will be broken out and removed. On the unleaded tank, saw cut and demo over the unleaded STP manhole and probe manhole (both 37" manholes.) Remove tank top sumps and properly dispose of all excavated material.
5. Saw cut and demo a trench approximately 4' wide x 142' long to expose existing piping.
6. Saw cuts approximately 5' x 15' around all islands. Site will be going islandless. When islands are demoed and removed, the existing storm drain will be removed from inside of island and will now drain from the base of the canopy onto concrete next to base. Electric running up canopy pole at dispenser 5/6 will be left alone and painted gray along with canopy pole.
7. Canopy bases will be exposed when existing islands are demoed. Neumayer assumes that all bases are, structurally, in good condition, and will not be compromised when exposed. If canopy bases are not in good condition, and require support brackets to be installed, the additional cost of equipment and labor to install brackets will be billed via Change Order.
8. Saw cut and demo a trench approximately 3' wide x 90' long from building to between dispensers 1/2 and 3/4 for new dispenser wires and conduit and a 3' wide x 30' long trench from between dispensers 5/6 and 7/8 to tank pad for new conduit for STP power, sump sensors, and probes.
9. This quote includes removal and replacement of approximately 2,300 square feet of concrete. Any additional removal and replacement of concrete will be billed via change order.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc.
5060 Arsenal Street
St. Louis, MO 63139

Contact Person: Jimmy Spiros
Phone: (314) 772-4501
Contractor Registration # IL1502 Exp. 3/26/2024

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File