



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 1027498
Permit # 00251-2023REM
Request Rec'd 03/07/2023
Amended Date
Approval Date 3/7/2023 DS
Permit Expires 9/7/2023

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Mac's Convenience Stores, LLC 1100 Situs Court, Suite 100 Raleigh, NC 27606</p> <p>Contact: Elizabeth Patterson (984) 389-1765</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Circle K #1436 2210 Locust Sterling, IL 61081</p> <p>Contact: Aprylle Tapley (217) 625-8034</p>
---	--

(3) REMOVAL OF TANKS:

- (a) Number and size of tanks being removed: (TK # 1) - 8,000, (TK # 2) - 10,000, (TK # 3) - 12,000*
- (b) Description/location of piping being removed:*
- (c) Product to be stored in each tank: (TK # 1, 3) - Gasoline - Regular, (TK # 2) - Gasoline - Premium*
- (d) Reason of tanks being removed:*
- (e) If tank(s) is leaking, indicate IEMA incident number:*
- (f) Date each tank was last used: (TK # 1, 2, 3) - Unknown*

- (4)** The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.
- (5) SPECIAL CONTINGENCIES** : 2. Disconnect the product piping and electrical supply from the four (4) Gilbarco Encore dispensers. Plug the inlets and remove the dispensers from the islands. Set dispensers to the side for re-installation.
3. Blow the fuel back to the underground storage tanks and shut off fuel supply.
4. Saw cut and demo an approximate 10' x 10' area around each of the three (3) STP manholes. Demo concrete and remove spoils from site for disposal.
5. Chase the product supply lines and conduits from the tank pad to the dispensers. Saw cut, demo, and excavate the product and conduit ditch, an approximate 10' x 65' trench. Product supply piping will not be disturbed and will remain in place.
6. Chase the electrical conduits back to the rear of the store. Saw cut, demo and excavate the trench to the conduit entry point at the rear of the building.
7. Remove all electrical conduits from the STP's and dispensers back to the rear of the store building. All conduit and wire will be replaced.
8. Demo all four (4) islands and remove spoils from site.
9. Cut the product supply lines back from each dispenser location far enough to install new sumps.
10. Remove all four (4) existing sumps and haul from site for proper disposal.
11. Excavate down to the three (3) tank tops and expose the three (3) existing STP sumps.
12. Disconnect the product piping and electric to the sub units.
13. Cut the product lines and conduits back far enough for sump replacement.
14. Remove the sub units and set aside for re-installation.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc.
5060 Arsenal Street
St. Louis, MO 63139

Contact Person: Jimmy Spiros
Phone: (314) 772-4501
Contractor Registration # IL1502 Exp. 3/26/2024

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File