



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 4033974
Permit # 00252-2023UPG
Request Rec'd 03/07/2023
Amended Date
Approval Date 3/7/2023 DS
Permit Expires 9/7/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: KPM Investments, Inc. 1001 Elgin Avenue Forest Park, IL 60130 Contact: Lukose Pattiyal (708) 415-6827	(2) FACILITY - name and address where tanks are located: LeRoy Travel Plaza 805 S. Hemlock Le Roy, IL 61752 Contact: Lukose Pattiyal (708) 415-6827
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 3) - 12,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 3) Piping - Flexible Double Wall A.P.T. Poly Tech S175SC , (TK # 3) Piping - Ball Valves , (TK # 3) Piping - Shear Valves , (TK # 3) Piping - Single Wall STP/Tanktop Sump , (TK # 3) Piping - Single Wall Transition Sump*
- (d) *Product to be stored in each tank: (TK # 3) - Diesel Fuel*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 3) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection, (TK # 3) Leak Detect - Piping - Non-Discriminating Sump Sensor in tank sump (if not existing) and in all new dispenser sumps as well as in transition sump*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Installing (3) New APT Dispenser Sumps with OPW 10P-0152 DP Sheer valves Franklin Fueling flex Connectors & Partial APT XP-175-SC DW Flex piping from the tank sump to Dispenser # 5/6, 7/8, 9/10 to transition sump . Installing three new Gilbarco Encore 700 S NP4 Ultra Hi Master/ Satellite Diesel Dispensers 2-sides. the existing diesel dispensers will remain at island # 11/12 & 13/14

Replaced piping exceeds 20 feet or 50% of the total pipe run.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:


Seneca Companies, Inc.

Contact Person: Glen Davis

4140 East 14th Street PO Box 3360
Des Moines, IA 50313

Phone: (816) 761-1270
Contractor Registration # IL598 Exp. 2/23/2024

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File