



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2036051  
Permit # 00260-2023REM  
Request Rec'd 03/06/2023  
Amended Date  
Approval Date 3/9/2023 DS  
Permit Expires 9/11/2023

**Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.**

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>DuPage Water Commission 600 E. Butterfield Rd. Elmhurst, IL 60126</p> <p>Contact: Mike Weed (630) 834-0100</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>DuPage Pumping Station 600 E. Butterfield Rd. Elmhurst, IL 60126</p> <p>Contact: Jason Unger (630) 834-0100</p>
---	--

(3) **REMOVAL OF PIPING:**

- (a) *Description/location of piping being removed:*
- (b) *Which tank(s) are associated with the piping being removed: (TK # 5) - 50,000*
- (c) *Reason of piping being removed:*
- (d) *If piping is leaking, indicate IEMA incident number:*

- (4) After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.
- (5) **SPECIAL CONTINGENCIES** : Removing a pipe from the fuel system that ran from a transition sump to a temporary generator location withing the building. The flexible double wall pipe is partially under the floor of the genrator building. The double wall flex pipe is in a sleeve/duct which will allow the pipe to be pulled from the building in one piece leaving the duct in place. The trench outside the building will be tested for contamination.

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Crowne Industries, Ltd.  
651 S. Sutton Road #214  
Streamwood, IL 60107

Contact Person: Robert Sumoski  
Phone: (630) 497-9009  
Contractor Registration # IL002345 Exp. 9/8/2023

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File