



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2006990
Permit # 00294-2023REM
Request Rec'd 03/15/2023
Amended Date
Approval Date 3/15/2023 DS
Permit Expires 9/15/2023

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

| | |
|--|--|
| <p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>RDK Ventures, LLC 550 Warrenville Rd., Suite 400 Lisle, IL 60532</p> <p>Contact: Elizabeth Patterson (984) 389-1765</p> | <p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Circle K #6759 6405 West Roosevelt Rd. Berwyn, IL 60402</p> <p>Contact: Laraze Simpson (630) 276-4268</p> |
|--|--|

(3) REMOVAL OF PIPING:

- (a) Description/location of piping being removed:*
- (b) Which tank(s) are associated with the piping being removed: (TK # 5, 6, 7) - 10,000*
- (c) Reason of piping being removed:*
- (d) If piping is leaking, indicate IEMA incident number:*

(4) After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) SPECIAL CONTINGENCIES : Remove all piping as it is not double wall fiberglass. Will submit a new piping layout as soon as it is available.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Anderson Pump Service, Inc.
19659 South 97th Avenue
Mokena, IL 60448

Contact Person: Hoyt Ary
Phone: (708) 478-6190
Contractor Registration # IL002275 Exp. 6/10/2023

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File