



Office of the Illinois State Fire Marshal
 Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 2177851020

FOR OFFICE USE ONLY
 Facility # 2010023
 Permit # 01367-2022UPG
 Request Rec'd 12/15/2022
 Amended Date 04/01/2023 DS
 Approval Date 12/15/2022 DS
 Permit Expires 6/15/2023

Revised

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Sibley Gas & Minimart 1650 Sibley Avenue Calumet City, IL 60409</p> <p>Contact: Mohamed M. Muthana (708) 891-2565</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Sibley Gas & Minimart 1650 Sibley Avenue Calumet City, IL 60409</p> <p>Contact: Mohamed M. Muthana (708) 891-2565</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 3, 4) - 12,000*
- (b) *Type of tanks:*
- (c) *Type of piping:*
- (d) *Product to be stored in each tank: (TK # 3) - Gasoline - Regular, (TK # 4) - Gasoline - Premium*
- (e) *Type of leak detection being used:*
 - Tank: (TK # 3, 4) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 Plus , (TK # 3, 4, 4) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 Plus with CSLD*
 - Piping: (TK # 3, 4) Leak Detect - Piping - Electronic Pressurized Line Leak Detection*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices: (TK # 3, 4) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Amendment Reason: Stp containment and dispenser containment we do on separate permit we have to replace piping for double wall and same time we change all contaminants. Changed piping leak detection from MLLD to PLLD

Amendment Reason: Stp containment and dispenser containment we do on separate permit we have to replace piping for double wall and same time we change all contaminants


Revision Reason: Contractor changed leak detection for piping and did not include that on permit in amendment. Inspector Carben requested that this change be made to show the change

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

CAT Builders USA, Inc.
522 E. Dundee Road
Palatine, IL 60074

Contact Person: Jan kopytek
Phone: (630) 670-6280
Contractor Registration # IL002381 Exp. 5/6/2024

Sincerely,



Daniel G. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File