



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Technical Services  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)524-7605

FOR OFFICE USE ONLY  
Facility # 1-008340  
Permit # 00865-2007INS  
Request Rec'd 05/30/2007  
Amended Date  
Approval Date 6/19/2007 JC  
Permit Expires 12/19/2007

**Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Prophet Mini Mart Inc 101 Fairview Court Walnut, IL 61376  Contact: Dennis Johnson (815) 379-9467	<b>(2) FACILITY</b> - name and address where tanks are located:  Prophet Mini Mart 202 Washington St Prophetstown, Whiteside Co., IL  Contact: Dennis Johnson (815) 537-2561
--	--

**(3) INSTALLATION OF TANKS:**

- (a) Number and size of tanks being installed:** (TK # 7) - 10,000 gallons, (TK # 8) - 6,000 gallons
- (b) Type of tanks:** (TK # 7, 8) - (Installing) Glasteel II double wall composite
- (c) Type of piping:** (TK # 7, 8) - Existing partial non-corrosive flexible from the new transition sump to the existing islands, (TK # 7, 8) - (Installing) partial A.P.T. Poly Tech P175 SC double wall flexible from the new tanks to the new transition sump (ball valves will also be installed in this transition sump to manually control the new tank supply to the two existing islands).
- (d) Product to be stored in each tank:** (TK # 7) - Gasoline, (TK # 8) - E-85
- (e) Type of leak detection being used:**
  - Tank:** (TK # 7, 8) - (Installing) Incon TS 750 automatic tank gauge, (TK # 7, 8) - (Installing) Veeder Root TLS 350 interstitial tank sensor
  - Piping:** (TK # 7, 8) - (Installing) FE Petro STP-MLD-E mechanical line leak detector (see contingencies), (TK # 7, 8) - (Installing) Veeder Root TLS350 interstitial piping sump sensors at the new tank submersible sumps and at the two new dispenser sumps.
- (f) Corrosion Protection being used:**
  - Tank:** (TK # 7, 8) - (Installing) Composite
  - Piping:** (TK # 7, 8) - Existing partial non-corrosive flexible, (TK # 7, 8) - (Installing) patial Non-corrosive flexible
- (g) Spill containment devices:**
- (h) Overfill prevention devices:**

- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.**

**(5) GENERAL REQUIREMENTS:**

**(6) SPECIAL CONTINGENCIES:**

<b>(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u></b>          Contact Person: Rob Vyncke Phone:  Contractor Registration #    Exp.
---

Sincerely,

