

### Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE**.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
Vandalia Green Energy, Inc. 1202 North Keller Drive, P. O. Box 70 Effingham, IL 62401	F.S. Travel Center #10 Interstate Drive Vandalia, Fayette Co., IL
Contact:	Contact:

# (3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: (TK # 1, 2) 20,000 gallons, (TK # 3) 15,000 gallons, (TK # 4, 5) 12,000 gallons
- (b) Type of tanks: (TK # 1, 2, 3, 4, 5) (Installing) Containment Solutions single wall fiberglass
- (c) Type of piping: (TK # 1, 2, 3, 4, 5) (Installing) A.P.T. Poly Tech P175 SC double wall flexible
- (d) Product to be stored in each tank: (TK # 1, 2) Diesel Fuel, (TK # 3, 4) Gasoline, (TK # 5) E-85
- (e) Type of leak detection being used:

Tank: (TK # 1, 2, 3, 4, 5) - (Installing) Incon TS-550 automatic tank gauge

Piping: (TK # 1, 2, 3, 4, 5) - (Installing) FE Petro STP-MLD-E mechanical line leak detector

(f) Corrosion Protection being used:

Tank: (TK # 1, 2, 3, 4, 5) - (Installing) Fiberglass

*Piping:* (TK # 1, 2, 3, 4, 5) - (Installing) Non-corrosive flexible

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at <u>www.state.il.us/osfm</u> or by calling (217)785-1020.

#### (5) GENERAL REQUIREMENTS:

# (6) <u>SPECIAL CONTINGENCIES</u>:

#### (7) PERSON, FIRM OR COMPANY PERFORMING WORK:

Contact Person: Kent Moore Phone:

Contractor Registration # Exp.

Sincerely,

Jame & Coffey

cc: Storage Tank Safety Specialist -Fire Department -Office Coordinator -Division File (Rev. - 1/98)