



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Technical Services**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)524-7605

<b>FOR OFFICE USE ONLY</b>
Facility # 2-011488
Permit # 00806-2007INS
Request Rec'd 06/06/2007
Amended Date
Approval Date 6/8/2007 JC
Permit Expires 12/8/2007

**Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Power Mart Company Operations        1301 W. 22nd Street, Suite 1005        Oak Brook, IL 60523        Contact: Nicole DiFiore (630) 571-6050</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Power Mart Company Operations Co.        6400 W. 127th Street        Palos Heights, Cook Co., IL        Contact: Nicole DiFiore (630) 571-6050</p>
---	--

**(3) INSTALLATION OF TANKS:**

- (a) **Number and size of tanks being installed:** (TK # 6) - 5,000 gallons
- (b) **Type of tanks:** (TK # 6) - (Installing) Containment Solutions double wall fiberglass
- (c) **Type of piping:** (TK # 6) - (Installing) A.P.T. Poly Tech P175 SC double wall flexible, (TK # 6) - (Installing) A.P.T. Poly Tech DCT-400 secondary chase piping (per site plan description).
- (d) **Product to be stored in each tank:** (TK # 6) - E-85
- (e) **Type of leak detection being used:**
  - Tank:** (TK # 6) - (Installing) Veeder Root TLS350 automatic tank gauge probe and module only (site has an existing tank gauge console).
  - Piping:** (TK # 6) - (Installing) Veeder Root TLS350 electronic line leak detector, (TK # 6) - (Installing) Veeder Root TLS350 interstitial piping sump sensors at submersible sump and dispenser sump.
- (f) **Corrosion Protection being used:**
  - Tank:** (TK # 6) - (Installing) Fiberglass
  - Piping:** (TK # 6) - (Installing) Non-corrosive flexible
- (g) **Spill containment devices:**
- (h) **Overfill prevention devices:**

**(4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.**

**(5) GENERAL REQUIREMENTS:**

**(6) SPECIAL CONTINGENCIES:**

<p><b>(7) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p> <p align="right">Contact Person: Doug Harmon        Phone:        Contractor Registration #    Exp.</p>
--

Sincerely,

*James J. Coffey*

cc: Storage Tank Safety Specialist -  
 Fire Department -  
 Office Coordinator -  
 Division File  
 (Rev. - 1/98)