



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Technical Services**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)524-7605

<b>FOR OFFICE USE ONLY</b>
Facility # 4-012377
Permit # 00785-2007FLX
Request Rec'd 06/05/2007
Amended Date
Approval Date 6/5/2007 DS
Permit Expires 12/5/2007

**Permit for UPGRADE or REPAIR of FLEX CONNECTOR for existing Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair flex connector(s) is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for flex connector of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Colonial Pantry, LTD          716 South Randolph Street, P.O. Box 1004          Champaign, IL 61820</p> <p>Contact: Patrick Miller (217) 352-6789</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Colonial Pantry #10          S.E. Corner I-74 &amp; Collison Road          Oakwood, Vermilion Co., IL</p> <p>Contact: John Miller (217) 352-6789</p>
---	--

**(3) UPGRADE OR REPAIR OF FLEX CONNECTORS:**

- (a) Number and size of tanks being upgraded or repaired:* (TK # 6) - 10,000 gallons
- (b) Type of flex connector(s):* (TK # 6) - (Installing) Steel flex connectors to replace leaking flex connector under dispenser #3
- (c) Product stored in each tank:* (TK # 6) - Diesel Fuel
- (d) Corrosion Protection being installed with flex connector(s):*

**(4) The owner must notify this Office when completion of flex connector upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for flex connector to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.**

**(5) SPECIAL CONTINGENCIES:**

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p> <p>Seneca Oil and Equipment          458 N. Hwy. 48, PO Box 60          Oreana, IL 62554</p>	<p>Contact Person: Chuck Hoenig          Phone:          Contractor Registration #    Exp.</p>
---	--

Sincerely,

cc: Storage Tank Safety Specialist -  
 Fire Department -  
 Office Coordinator -  
 Division File  
 (Rev. - 1/98)