

OFFICE OF THE ILLINOIS STATE FIRE MARSHAL Division of Technical Services

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

FOR OFFICE USE ONLY

Facility # 6-000133
Permit # 00774-2007INS
Request Rec'd 05/09/2007
Amended Date
Approval Date 6/4/2007 JC
Permit Expires 12/4/2007

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE**.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
Dickerson Petroleum, Inc. 920 N. Illinois Street Belleville, IL 62220	Gas Mart #35 6001 W. Main Belleville, St. Clair Co., IL
Contact: Steve Dickerson (618) 233-0786 Ext.	Contact: Tom Wueller (618) 233-0786

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: One compartment tank consisting of (TK # 9) 20,000 gallons, (TK # 10) 6,000 gallons
- (b) Type of tanks: (TK # 9, 10) (Installing) XERXES single wall fiberglass
- (c) Type of piping: (TK # 9, 10) (Installing) partial Ameron Dualoy 3000/LCX double wall fiberglass from tanks to new transition sumps (SEE CONTINGENCIES), (TK # 9, 10) Existing single wall fiberglass to remain from dispensers to new transition sumps.
- (d) Product to be stored in each tank: (TK # 9, 10) Gasoline
- (e) Type of leak detection being used:

Tank: (TK # 9, 10) - Existing automatic tank gauging to be re-used from the abandoned tanks.

Piping: (TK # 9, 10) - (Installing) Red Jacket FX1 mechanical line leak detector

(f) Corrosion Protection being used:

Tank: (TK # 9, 10) - (Installing) Fiberglass

Piping: (TK # 9, 10) - Existing fiberglass, (TK # 9, 10) - (Installing) Non-corrosive flexible

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.
- (5) GENERAL REQUIREMENTS:
- (6) SPECIAL CONTINGENCIES:

(7) PERSON, FIRM OR COMPANY PERFORMING WORK:	
	Contact Person: Bob Barbee Phone:
	Contractor Registration # Exp.

Sincerely,

James J Coffey

cc: Storage Tank Safety Specialist -Fire Department -Office Coordinator -Division File (Rev. - 1/98)