



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-010919
Permit # 00760-2007UPG
Request Rec'd 05/29/2007
Amended Date
Approval Date 5/31/2007 JC
Permit Expires 11/30/2007

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE**

APPROVAL DATE.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Wagemann Oil Co. 381 E. St. Charles Rd. Carol Stream, IL 60188 Contact: Peter Spina (630) 668-0141	(2) FACILITY - name and address where tanks are located: Villa Park Citgo 151 W North Ave Villa Park, Du Page Co., IL Contact: Mancini Peter (708) 584-2505
--	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired:* (TK # 4) - 12,000 gallons, (TK # 5) - 10,000 gallons, (TK # 6) - 15,000 gallons

(b) *Type of tanks:*

(c) *Type of piping:* Contractor will be removing the far northeast and the far northwest dispenser island, and he will replace these two islands / dispensers with 3 + 1 blender MPD's; consequently, the dispenser box will be "re-routed" to accommodate the new MPD's. Furthermore, there will be a small / partial amount of piping installed to accommodate this job. The partial sections will hook into the existing piping. It is unclear in our records whether the existing piping is single wall fiberglass or double wall fiberglass. Also, the contractor proposes to break out and replace the southwest island form and replace the form in the same (original) location. No piping or electrical work is needed for the southwest island form work.

(d) *Product to be stored in each tank:* (TK # 4) - Diesel Fuel, (TK # 5, 6) - Gasoline

(e) *Type of leak detection being used:*

Tank:

Piping:

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Steve Tuttle Phone: Contractor Registration # Exp.
--

Sincerely,

Jim Coffey

