

OFFICE OF THE ILLINOIS STATE FIRE MARSHAL Division of Technical Services 1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
BP Products North America, Inc. P. O. Box 6038, Environmental Compliance Dept. Artesia, CA 90702	Amoco Ss#15989 Fac#11617 6820 Rt. 53 Woodridge, Du Page Co., IL
Contact: Jennifer Sosin (630) 980-1810	Contact: Mike Kocon (630) 836-5553

(3) <u>UPGRADE OR REPAIR OF TANKS:</u>

- (a) Number and size of tanks being upgraded or repaired: (TK # 7) 12,000 gallons
- (b) Type of tanks:
- (c) Type of piping:
- (d) Product to be stored in each tank: (TK # 7) Gasoline
- (e) Type of leak detection being used:

Tank:

Piping: (TK # 7) - (Installing) Veeder Root TLS350 interstitial piping sump sensor at submersible sump to replace existing failed sensor

(f) Corrosion Protection being used:

Tank:

Piping:

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (i) Manway accessible at grade:
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at <u>www.state.il.us/osfm</u> or by calling (217)785-1020.

(5) <u>SPECIAL CONTINGENCIES</u>:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Contact Person: Ed Angell Phone:

Contractor Registration # Exp.

Sincerely,

James J Coffey

Jim Coffey

cc: Storage Tank Safety Specialist -Fire Department -Office Coordinator -Division File (Rev. - 1/98)