



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Technical Services  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)524-7605

FOR OFFICE USE ONLY  
Facility # 1-034915  
Permit # 00725-2007UPG  
Request Rec'd 05/22/2007  
Amended Date  
Approval Date 5/22/2007 JC  
Permit Expires 11/22/2007

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Kelley Williamson Company 1132 Harrison Avenue Rockford, IL 61104 Contact: Bob Sanders (815) 397-9410	<b>(2) FACILITY</b> - name and address where tanks are located: Belvidere Mobil Mart 1776 Logan Ave Belvidere, Boone Co., IL Contact: Griffin John (815) 397-9410
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1) - 12,000 gallons, (TK # 2, 3) - 8,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 1, 2, 3) - (Installing) partial Ameron Dualoy 3000/LCX double wall fiberglass to accommodate the relocation of the existing dispensers at each end of the canopy (the dispensers / islands in between the end dispensers / islands will remain). The existing end dispensers will be moved to the south of the canopy columns. New dispensers will be installed to the north of the canopy columns. New transition sumps (2) will be installed where the original end islands were, and will connect the existing piping to the new partial piping. The new dispensers will have OPW Piceses containment sumps installed. (See site plan for graphic details).
- (d) *Product to be stored in each tank:* (TK # 1, 2, 3) - Gasoline
- (e) *Type of leak detection being used:*  
*Tank:*  
*Piping:*
- (f) *Corrosion Protection being used:*  
*Tank:*  
*Piping:*
- (g) *Spill containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES:**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>          Contact Person: Nate Meyer Phone:  Contractor Registration #    Exp.
--

Sincerely,

Jim Coffey

