



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

**Amended**

FOR OFFICE USE ONLY  
Facility # 2-029564  
Permit # 01082-2012UPG  
Request Rec'd 10/11/2012  
**Amended Date 10/25/2012**  
Approval Date 10/16/2012 JC  
Permit Expires 4/16/2013

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Advocate Healthcare 2025 Windsor Drive Oak Brook, IL 60523-1586 Contact: John Helin (630) 275-5900	<b>(2) FACILITY</b> - name and address where tanks are located: Good Samaritan Hospital 3815 Highland Ave Downers Grove, Du Page Co., IL Contact: Joe Kybartas (630) 275-1086
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired:* (TK # 2) - 4,000 gallons
- (b) Type of tanks:*
- (c) Type of piping:* (TK # 2) - (Installing) Chase Secondary piping A.P.T. Poly Tech DCT-400 , (TK # 2) - (Installing) Tank piping sump containment FRP to replace the existing sump, (TK # 2) - (Installing) Flexible Double Wall A.P.T. Poly Tech P200SC supply and return line for a new generator. The existing generator and associated piping will remain.
- (d) Product to be stored in each tank:* (TK # 2) - Diesel Fuel
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping:* (TK # 2) - (Installing) European with No Test Req Suction. Section 175.640(b)(2)(E) must be adhered to for present and future verification of European suction. According to the contractor, there is an existing sump sensor at the tank sump.
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:* (TK # 2) - (Installing) Fiberglass Non-Corrosive chase duct piping , (TK # 2) - (Installing) Flexible Non-Corrosive product piping.
- (g) Spill containment devices, piping, and dispenser containment devices:* (TK # 2) - (Installing) Manhole Pre-manufactured EBW 705
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES:**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>  Schaumburg, IL 60194	Contact Person: Robert Sumoski Phone: (630) 497-9009  Contractor Registration # Exp.
---	---

Sincerely,

Jim Coffey

