



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

FOR OFFICE USE ONLY  
Facility # 1-007420  
Permit # 01137-2012UPG  
Request Rec'd 10/24/2012  
Amended Date  
Approval Date 10/24/2012 DS  
Permit Expires 4/24/2013

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Road Ranger, LLC P.O. Box 4745 Rockford, IL 61110 Contact: Hope Collins (815) 387-1700	<b>(2) FACILITY</b> - name and address where tanks are located: Road Ranger #231 10114 North 2nd Street Machesney Park, Winnebago Co., IL Contact: Tanna Dittorf (815) 997-1068
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 4) - 15,000 gallons, (TK # 5) - 8,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 4, 5) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX to replace existing product piping
- (d) *Product to be stored in each tank:* (TK # 4, 5) - Gasoline
- (e) *Type of leak detection being used:*
  - Tank:** (TK # 4, 5) - (Installing) Interstitial Monitoring Veeder Root TLS 350 to existing TLS 350 ATG
  - Piping:** (TK # 4, 5) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 in all submersible and all dispenser sumps, (TK # 4, 5) - (Installing) Mechanical Pressurized Line Leak Detection FE Petro STP-MLD
- (f) *Corrosion Protection being used:*
  - Tank:**
  - Piping:** (TK # 4, 5) - (Installing) Fiberglass Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:* (TK # 4, 5) - (Installing) Manhole Pre-manufactured OPW ISC-2100C 5 gallon
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES:**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>  Rockford, IL 61104	Contact Person: Nate Meyer Phone: (815) 398-6250  Contractor Registration # Exp.
---	---

Sincerely,

Daniel Starks

