



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 3-043628
Permit # 00668-2007INS
Request Rec'd 05/14/2007
Amended Date
Approval Date 5/14/2007 JC
Permit Expires 11/14/2007

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Kroger Company 5960 Castleway West Dr. Indianapolis, IN 46250 Contact: Nick Bondar (317) 579-8281	(2) FACILITY - name and address where tanks are located: Kroger Fuel Center #J918 9219 N. Lindbergh Dr. Peoria, Peoria Co., IL Contact:
---	--

(3) INSTALLATION OF TANKS:

- (a) **Number and size of tanks being installed:** (1) compartment tank consisting of: (TK # 1) - 8,000 gallons, (TK # 2) - 20,000 gallons
- (b) **Type of tanks:** (TK # 1, 2) - (Installing) XERXES double wall fiberglass brine filled
- (c) **Type of piping:** (TK # 1, 2) - (Installing) A.P.T. Poly Tech P150SC double wall flexible, (TK # 1, 2) - (Installing) A.P.T. Poly Tech DCT-400 secondary chase piping.
- (d) **Product to be stored in each tank:** (TK # 1, 2) - Gasoline
- (e) **Type of leak detection being used:**
Tank: (TK # 1, 2) - (Installing) Veeder Root TLS 350 with CSLD automatic tank gauge probes for inventory purposes only, (TK # 1, 2) - (Installing) Veeder Root TLS 350 hydrostatic reservoir sensor for tank leak detection
Piping: (TK # 1, 2) - (Installing) Veeder Root TLS350 interstitial piping sump sensors at all dispenser sumps and all submersible sumps, (TK # 1, 2) - (Installing) Veeder Root TLS350 electronic line leak detector
- (f) **Corrosion Protection being used:**
Tank: (TK # 1, 2) - (Installing) Fiberglass
Piping: (TK # 1, 2) - (Installing) Fiberglass secondary containment, (TK # 1, 2) - (Installing) Non-corrosive flexible
- (g) **Spill containment devices:**
- (h) **Overfill prevention devices:**

- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

- (5) **GENERAL REQUIREMENTS:** There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons.

- (6) **SPECIAL CONTINGENCIES:**

(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Contact Person: Phone: Contractor Registration # Exp.
--

Sincerely,

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)