



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 2020654
Permit # 00316-2023ABN
Request Rec'd 03/21/2023
Amended Date 04/12/2023 DS
Approval Date 3/22/2023 DS
Permit Expires 9/22/2023

Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>M7 Oil Corporation 500 East Rollins Road Ingleside, IL 60041</p> <p>Contact: Jacob Plamparapil (847) 410-2661</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>M7 Oil Corporation 500 East Rollins Road Ingleside, IL 600419701</p> <p>Contact: Jacob Plamparapil (773) 715-5480</p>
--	--

(3) **ABANDONMENT IN PLACE OF TANKS:**

(a) *Number and size tanks being abandoned: (TK # 7) - 8,000*

(b) *Product stored in each tank: (TK # 7) - Gasoline - Regular*

(c) *Location of tanks being abandoned:*

As the contractor, we feel that the proposed UST being decommissioned is in a vulnerable location being adjacent to another UST while also being adjacent to the canopy. The space will be limited for heavy equipment to be able to pull the tank out being right next to the canopy structure. With that in mind, we feel it is safer to the surrounding USTs and structures that we continue with an in place closure. Another factor that is also considered is that there are several product lines running over the the proposed tank that would need to be removed and re piped as a result of trying to pull the tank vs in place closure. Please advise if any thing is missing or needed to get the permit for this job

Thank you

Innovative Team

(d) *Location of piping being abandoned:*

(4) This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.

(5) **SPECIAL CONTINGENCIES :**

As the contractor, we feel that the proposed UST being decommissioned is in a vulnerable location being adjacent to another UST while also being adjacent to the canopy. The space will be limited for heavy equipment to be able to pull the tank out being right next to the canopy structure. With that in mind, we feel it is safer to the surrounding USTs and structures that we continue with an in place closure. Another factor that is also considered is that there are several product lines running over the the proposed tank that would need to be removed and re piped as a result of trying to pull the tank vs in place closure. Please advise if any thing is missing or needed to get the permit for this job

Thank you

Innovative Team

Amendment Reason: Wrong tank number was mentioned in permit, correcting the tank number to 7


(6) **The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.**

(7) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Innovative Constructions Technology LLC
3112 AVIARA CT NAPERVILLE IL
Naperville, IL 60564

Contact Person: RAMACHANDRA RAJ penumatsa
Phone: (630) 747-3404
Contractor Registration # IL002453 Exp. 2/7/2024

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File