



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2042394  
Permit # 00390-2023UPG  
Request Rec'd 04/17/2023  
Amended Date  
Approval Date 4/17/2023 DS  
Permit Expires 10/17/2023

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Grab & Go, Inc. 1701 Kenosha Rd. Zion, IL 60099  Contact: Shehan Isam (773) 964-9902	<b>(2) FACILITY</b> - name and address where tanks are located:  Grab & Go 1701 Kenosha Road Zion, IL 60099  Contact: Shehan Isam (773) 964-9902
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1) - 12,000, (TK # 2) - 6,000, (TK # 3) - 4,000*
- (b) *Type of tanks:*
- (c) *Type of piping:*
- (d) *Product to be stored in each tank: (TK # 1) - Gasoline - Regular, (TK # 2) - Gasoline - Premium, (TK # 3) - Diesel Fuel*
- (e) *Type of leak detection being used:*
  - Tank: (TK # 1, 2, 3) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 Plus with CSLD*
  - Piping: (TK # 2) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection*
- (f) *Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES** : Remove Incon TS1001 from leak detection and install TLS350 Plus with CSLD, change all probes to water detection and .1 test capabilities. Remove incon electronic leak detector from Premium tank, install and test new mechanical leak detector.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Big Daddy Pump & Compliance  
301 Main St Unit 105  
Antioch, IL 60073

Contact Person: Billy Umphrey  
Phone: (352) 901-4467  
Contractor Registration # IL002457 Exp. 12/2/2024

Sincerely,

*Daniel G. Starks*

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File