



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 2010267
Permit # 00383-2023UPG
Request Rec'd 04/12/2023
Amended Date 04/19/2023 DS
Approval Date 4/13/2023 DS
Permit Expires 10/13/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Ranchhodji1723, LLC 1050 E. New York Street Aurora, IL 60505 Contact: Kiran Patel (630) 818-7394	(2) FACILITY - name and address where tanks are located: Ranchhodji1723, LLC 1050 E. New York St. Aurora, IL 60505 Contact: Kiran Patel (630) 818-7394
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 3, 4) - 12,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 3) Piping - Fiberglass Single Wall Piping*
- (d) *Product to be stored in each tank: (TK # 3) - Gasoline - Premium, (TK # 4) - Gasoline - Regular*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices: (TK # 3, 4) Spill Contain Device - Single Wall Spill Bucket*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Both spill buckets and risers need to be replaced. Thank you

Vent line was damaged during riser change on premium tank. Cutting and replacing 2 feet of vent pipe

Amendment Reason: Vent line was damaged during riser change on premium tank. Cutting and replacing 2 feet of vent pipe

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Innovative Constructions Technology LLC
3112 AVIARA CT NAPERVILLE IL
Naperville, IL 60564

Contact Person: RAMACHANDRA RAJ penumatsa
Phone: (630) 747-3404
Contractor Registration # IL002453 Exp. 2/7/2024

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File