



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2034434
Permit # 00424-2023UPG
Request Rec'd 04/24/2023
Amended Date
Approval Date 4/24/2023 DS
Permit Expires 10/24/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Speedway, LLC P.O. Box 1500 Springfield, OH 45501 Contact: Zachary Davis (937) 203-7827	(2) FACILITY - name and address where tanks are located: Speedway #1412 19730 S. Harlem Ave. Frankfort, IL 604238692 Contact: Amanda Kamp (708) 479-8592
--	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 1) - 20,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 1) Piping - Other Steel Riser*

(d) *Product to be stored in each tank: (TK # 1) - Gasoline - Regular*

(e) *Type of leak detection being used:*

Tank:

Piping:

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices: (TK # 1) Spill Contain Device - Single Wall Spill Bucket*

(h) *Overfill prevention devices: (TK # 1) Overfill Prev Device - Overfill Drop Tube Valve*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

The spill bucket is cracked according to testing contractor so replacing the riser, spill and drop tube

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

America Petropump Services LLC d/b/a Ampsco Services
4075 Fox Valley Center Dr., Unit 9
Aurora, IL 60504

Contact Person: Ravindra Penmatsa
Phone: (312) 286-6722
Contractor Registration # IL002420 Exp. 5/22/2023

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File