



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 6002467
Permit # 00426-2023UPG
Request Rec'd 04/24/2023
Amended Date
Approval Date 4/24/2023 DS
Permit Expires 10/24/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: South Central FS, Inc. 405 S. Banker Street P.O. Box 629 Effingham, IL 62401 Contact: Joseph Meinhart (217) 342-9231	(2) FACILITY - name and address where tanks are located: South Central FS, Inc. 1800 Hillsboro Road Vandalia, IL 62471 Contact: Tina Tinker (618) 283-1368
---	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 9) - 12,000, (TK # 10) - 8,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 9, 10) Piping - Flexible Double Wall A.P.T. Poly Tech P175SC*

(d) *Product to be stored in each tank: (TK # 9) - B-11, (TK # 10) - Gasoline - Non Ethanol*

(e) *Type of leak detection being used:*

Tank:

Piping:

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Replacing the damaged diesel line between dispenser 9 & 10 island to the #10 slave island.

(Ref: NOV E0020230097)

NOTE: Sumps and sensors must be existing or they must be installed

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Pemco Service Company, Inc.
1040 East Second Street
Gilman, IL 60938

Contact Person: William "Butch" VonDrehle
Phone: (815) 265-7364
Contractor Registration # IL1224 Exp. 2/26/2024

Sincerely,

Daniel G. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File