



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 5047577
Permit # 00433-2023INS
Request Rec'd 04/25/2023
Amended Date
Approval Date 4/25/2023 DS
Permit Expires 10/25/2023

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Wortman Holdings, LLC P.O. Box 217 Effingham, IL 62401 Contact: Lisa Wortman (217) 342-7291	(2) FACILITY - name and address where tanks are located: Jack Flash Pana 11 South Poplar Street Pana, IL 62557 Contact: John Wortman (217) 342-7291
---	--

(3) INSTALLATION OF TANKS:

- (a) *Number and size of tanks being installed: (TK # 1, 4) - 20,000, (TK # 2) - 5,000, (TK # 3) - 10,000*
- (b) *Type of tank(s): (TK # 1, 2, 3, 4) Tank - Composite Double Wall Lannon*
- (c) *Type of piping: (TK # 1, 2, 3, 4) Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000L for vents, (TK # 1, 2, 3, 4) Piping - Flexible Double Wall OPW Flexworks from tanks to dispensers, (TK # 1, 2, 3, 4) Piping - Single Wall STP/Tanktop Sump*
- (d) *Product to be stored in each tank: (TK # 1) - Gasoline - Regular, (TK # 2) - Gasoline - Premium, (TK # 3) - Diesel Fuel, (TK # 4) - B-II*
- (e) *Type of leak detection being used:*
 - Tank: (TK # 1, 2, 3, 4) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus, (TK # 1, 2, 3, 4) Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors*
 - Piping: (TK # 1, 2, 3, 4) Leak Detect - Piping - Electronic Pressurized Line Leak Detection, (TK # 1, 2, 3, 4) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown in all submersible and dispenser sumps*
- (f) *Corrosion Protection being used:*
 - Tank: (TK # 1, 2, 3, 4) Corrosion Prot - Tank - Composite Non-Corrosive*
 - Piping: (TK # 1, 2, 3, 4) Corrosion Prot - Piping - Flexible Non-Corrosive*
- (g) *Spill containment devices, piping and dispenser containment devices: (TK # 1, 2, 3, 4) Spill Contain Device - Single Wall Spill Bucket*
- (h) *Overfill prevention devices: (TK # 1, 2, 3, 4) Overfill Prev Device - Overfill Drop Tube Valve*

- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) **GENERAL REQUIREMENTS** : There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.
- (6) **SPECIAL CONTINGENCIES** :
New location. The site will have an auto canopy with 9 Wayne Ovation 2 dispensers and the truck diesel will have three fueling lanes with Master and Satellite dispensers and DEF at each master. The truck diesel is a 20,000 gallon Lannon composite tank and the DEF tank is 6,000

gallon FRP doublewall UL 1316 listed KBK tank. All product piping is OPW FlexWorks Loop System on both the auto and truck side. The auto side has a Lannon Composite DW 20,000 gallon Regular tank and a Lannon Composite DW 15,000 gallon compartment tank split 10k auto diesel/5k Premium. a Veeder Root TLS-450 Plus ATG will be installed with positive shutdown on sump sensors, EPLLD line leak detectors and tank interstitial sensors.


NOTES: A motor fuel dispensing permit must be applied for asap. Dispensers must maintain a full 10' from all buildings and property lines

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

UPC Enterprises, LC d/b/a United Petroleum Service
4444 Union Blvd.
St. Louis, MO 63115

Contact Person: Terry Smith
Phone: (314) 241-3767
Contractor Registration # IL002402 Exp. 2/10/2024

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File