



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 3007532  
Permit # 00481-2023ABN  
Request Rec'd 05/05/2023  
Amended Date  
Approval Date 5/7/2023 DS  
Permit Expires 11/8/2023

**Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Jesse Food Mart 275 S. Academy Street Galesburg, IL 61401</p> <p>Contact: Parminder Kaur Kaur (309) 221-4544</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Quick Stop One 275 South Academy Galesburg, IL 61401</p> <p>Contact: Parminder Kaur (309) 221-4544</p>
---	---

(3) **ABANDONMENT IN PLACE OF TANKS:**

- (a) *Number and size tanks being abandoned: (TK # 1) - 12,000, (TK # 2, 3) - 6,000*
- (b) *Product stored in each tank: (TK # 1) - Gasoline - Regular, (TK # 2) - Gasoline - Mid-grade, (TK # 3) - Gasoline - Premium*
- (c) *Location of tanks being abandoned:*  
*The end of the 12K UST is approximately 8 feet from the end of the building. The invert of the 12K UST is approximately 12 to 13 feet. Removal of this UST will most likely undermine the building. Removal of either of the two 6K UST would most likely cause the 12K UST to move and threaten foundation of the building. See Site Map*

**CONTAMINATED SITE! IEMA Number: 2023-0338**

(d) *Location of piping being abandoned:*

- (4) This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.
- (5) **SPECIAL CONTINGENCIES** : Piping being removed under a separate permit
- (6) **The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.**

(7) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

CW3M Company, Inc.  
701 West South Grand Avenue  
Springfield, IL 62704

Contact Person: Carol Rowe  
Phone: (217) 522-8001  
Contractor Registration # IL1723 Exp. 8/9/2024

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File