



Office of the Illinois State Fire Marshal
 Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 2177851020

FOR OFFICE USE ONLY
 Facility # 2046622
 Permit # 00517-2023UPG
 Request Rec'd 05/15/2023
 Amended Date
 Approval Date 5/15/2023 DS
 Permit Expires 11/15/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Lenny's Gas N Wash Sauk Trail, LLC 8200 185th St., Unit K Tinley Park, IL 60487</p> <p>Contact: Leonard McEnery (708) 805-2525</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Lenny's Gas N Wash Sauk Trail, LLC 1445 E. Sauk Trail Sauk Village, IL 60411</p> <p>Contact: Len McEnery (708) 805-2525</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 5) - 30,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 5) Piping - Shear Valves*
- (d) *Product to be stored in each tank: (TK # 5) - Diesel Fuel*
- (e) *Type of leak detection being used:*
 Tank:
 Piping:
- (f) *Corrosion Protection being used:*
 Tank:
 Piping:
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


(5) SPECIAL CONTINGENCIES :

Replace broken shear valve on dispenser 3 High Flo. Will have 3rd party line test before opening back up.

NOTE: A sump must be installed if one doesn't already exist

<p>(6) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u></p> <p>Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448</p>	<p>Contact Person: Ron Anderson Phone: (708) 478-6190 Contractor Registration # IL002275 Exp. 5/21/2024</p>
---	---

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File