



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2047408
Permit # 00522-2023INS
Request Rec'd 05/15/2023
Amended Date
Approval Date 5/16/2023 DS
Permit Expires 11/16/2023

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: UC Huntley LLC 1600 De Prizio Drive Melrose Park, IL 60160 Contact: Viktor Demyaniv (773) 304-4537	(2) FACILITY - name and address where tanks are located: Universe Carrier 14351 Weber Drive Huntley, IL 60142 Contact: Viktor Demyaniv (773) 543-9442
--	--

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: (TK # 1) - 12,000*
- (b) Type of tank(s): (TK # 1) Tank - Composite Double Wall Lannon*
- (c) Type of piping: (TK # 1) Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000L for vents, (TK # 1) Piping - Flexible Double Wall Franklin Fueling Systems UPP from tank to dispensers, (TK # 1) Piping - Other Submersible Pump, (TK # 1) Piping - Ball Valves , (TK # 1) Piping - Positive Shutoff Valves , (TK # 1) Piping - Shear Valves , (TK # 1) Piping - Single Wall STP/Tanktop Sump*
- (d) Product to be stored in each tank: (TK # 1) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank: (TK # 1) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus , (TK # 1) Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors*
 - Piping: (TK # 1) Leak Detect - Piping - Electronic Pressurized Line Leak Detection, (TK # 1) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown in submersible and dispenser sumps*
- (f) Corrosion Protection being used:*
 - Tank: (TK # 1) Corrosion Prot - Tank - Composite Non-Corrosive*
 - Piping: (TK # 1) Corrosion Prot - Piping - Flexible Non-Corrosive*
- (g) Spill containment devices, piping and dispenser containment devices: (TK # 1) Spill Contain Device - Double Wall Spill Bucket Remote Fill*
- (h) Overfill prevention devices: (TK # 1) Overfill Prev Device - Overfill Alarm*

- (4)** The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) GENERAL REQUIREMENTS** : There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

(6) SPECIAL CONTINGENCIES :

TANK: (1) 12,000 gallon double wall composite UST. (1) 1000 gallon AST DEF tank. Concrete dead men hold downs, straps & turnbuckles.

OVERSPILL/OVERFILL PREVENTION: (1) 5 gallon, below-grade spill containment manhole. (1) Overfill alarm with acknowledgement switch. (1) Diesel aluminum drop tube. SUMPS: (1) 42" fiberglass watertight tank top piping sump. (2) Fiberglass dispenser sumps at islands. PIPING: 2" Double wall UL UPP Pipe. Ameron 3" single wall fiberglass vent piping system.

SUBMERSIBLE PUMPS: (1) FE Petro 2 HP submersible pump with Electronic Line Leak Detector. (Diesel) (1) Diesel pump Controller.

LEAK DETECTION: (1) Veeder-Root TLS-450 monitor console. (1) 10' Tank level probe (Diesel). (1) Tank interstitial sensor, non-discriminating with positive shutdown. (2) Dispenser sump sensors, non-discriminating with positive shutdown. (1) Tank sump sensor, non-discriminating with positive shutdown. (1) Digital Pressurized line leak detector. (1) Overfill alarm with acknowledgement switch.

CONCRETE: Island- [1] 4'x 8' Island- [1] 3'x 5' Tank Pad- 64' x 14' x 8"

ISLAND EQUIPMENT: (1) Fire extinguisher. (1) E-stop switch at master dispenser and (1) on building. (8) 6" concrete filled steel bollards with yellow sleeves.

DISPENSERS: (1) Diesel dispenser. (1) Satellite dispenser.

CARD READER: PetroVend PV200 Enterprise system.


NOTES: Dispensers must maintain a full 10' from buildings and property lines. A motor fuel dispensing permit must be applied for asap.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Crowne Industries, Ltd.
651 S. Sutton Road #214
Streamwood, IL 60107

Contact Person: Robert Sumoski
Phone: (630) 497-9009
Contractor Registration # IL002345 Exp. 5/16/2024

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File