



Office of the Illinois State Fire Marshal
 Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 2177851020

FOR OFFICE USE ONLY
 Facility # 4008063
 Permit # 00533-2023ABN
 Request Rec'd 05/16/2023
 Amended Date
 Approval Date 5/17/2023 DS
 Permit Expires 11/17/2023

Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>GRD of Neoga, Inc. P.O. Box 816 Neoga, IL 62447</p> <p>Contact: Dave Antrim (217) 821-1850</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Neoga Truck Stop 1095 N. Rt. 45 Neoga, IL 62447</p> <p>Contact: Dave Antrim (217) 821-1850</p>
--	--

(3) ABANDONMENT IN PLACE OF TANKS:

(a) *Number and size tanks being abandoned: (TK # 2) - 10,000*

(b) *Product stored in each tank: (TK # 2) - Gasoline - Regular*

(c) *Location of tanks being abandoned:*

the existing 10,000 gallon tank is in the same tank pit as an active UST and would compromise the active tank if removed, so it is unsafe to remove the existing 10,000 gallon tank that is condemned. The piping will be abandoned as it is in the same trench as other active fuel piping. This is a justified reason to abandon this tank and piping in place.

CONTAMINATED SITE! IEMA Number: 2022-1000

(d) *Location of piping being abandoned: the existing 10,000 gallon tank is in the same tank pit as an active UST and would compromise the active tank if removed, so it is unsafe to remove the existing 10,000 gallon tank that is condemned. The piping will be abandoned as it is in the same trench as other active fuel piping. This is a justified reason to abandon this tank and piping in place.*

(4) This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.

(5) SPECIAL CONTINGENCIES :

(6) **The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.**

<p>(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u></p>	
<p>Perry Environmental, Inc. 2803 Old Rochester Road, Suite A Springfield, IL 62703</p>	<p>Contact Person: julie keebler Phone: (217) 523-5446 Contractor Registration # IL002445 Exp. 4/6/2024</p>

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
 Division File