



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 1017422
Permit #: 00570-2023LIN
Request Rec'd: 05/30/2023
Approval Date: 05/30/2023 DS
Permit Expires: 11/30/2023

Permit for INSPECTION OF INTERIOR LINING of Underground Storage Tank(s) for Petroleum and Hazardous Substances

Permission to inspect existing interior lining of underground storage tank(s) is hereby granted. Such inspections of interior lining must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. **THIS PERMIT IS FOR THE INTERIOR INSPECTION OF THE EXISTING LINING ONLY! NO REPAIRING, UPGRADING, OR INTERIOR LINING IS AUTHORIZED WITH THIS PERMIT.**

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: GPM Midwest, LLC 8565 Magellan Pkwy, Ste. 400 Richmond, VA 23227 (None) County Contact: Chad Fluck 317/914-9446	FACILITY - name and address where tanks are located: Fas Mart #5220 8096 Forest Hills Rd. Loves Park, IL 61111 Winnebago County Contact: Sara Swanson 815/315-4287
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status	Manway
4	Diesel Fuel	4,000	Currently in use	Federal	Existing

Summary of Work

Purge, clean and inspect the internal lining of the following tanks in accordance with State of Illinois 175 regulations:

Special Contingencies

Purge, clean and inspect the internal lining of the following tanks in accordance with NLPA-631 and State of Illinois 175 regulations:

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Armor Shield of Wisconsin 3965 Hillside Road Slinger, WI 53086	Contact Person: Clayton Bennett Phone: 262/623-0300 Email: paula@armorshieldus.com Contractor License # IL1707 Exp. 4/18/2024

Sincerely,

Daniel Starks