



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 3015109
Permit #: 00576-2023UPG
Request Rec'd: 05/30/2023
Approval Date: 05/30/2023 DS
Permit Expires: 11/30/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: S & R Oil Five, Inc. P.O. Box 285 New Boston, IL 61272 Mercer County Contact: Sean Chinna 319/572-4667	FACILITY - name and address where tanks are located: Bay C 402 6th Street New Boston, IL 61272 Mercer County Contact: Mamie McDonald 309/487-8345
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Premium	8,000	Currently in use	Federal
2	Gasoline - Regular	8,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Single Wall Piping Ameron	Replacing - Piping - Fiberglass Single Wall Piping

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Single Wall Piping Ameron	Replacing - Piping - Fiberglass Single Wall Piping

Summary of Work

this permit is to take the vent gal. pipe off c- store and cut fiberglass pipe and put the vent gal. pipe on the other small building next to c-store.

We will put extractor valves on each tank, and 4" pipe to grade and 18" manway coated and taped with anode on 4" pipe.

Special Contingencies

this permit is to take the vent gal. pipe off c- store and cut fiberglass pipe and put the vent gal. pipe on the other small building next to c-store.

We will put extractor valves on each tank, and 4" pipe to grade and 18" manway coated and taped with anode on 4" pipe. The customer is adding on to building is the reason for moving.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
R. L. Hoener Company 2923 Gardner Expressway P. O. Box 1086 Quincy, IL 62305	Contact Person: Marty Jackson Phone: 217/223-2190 Email: marty@rlhoener.com Contractor License # IL2021 Exp. 5/22/2024

Sincerely,

Daniel G. Starks

Daniel Starks