



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**

Facility #: 4018394  
Permit #: 00578-2023UPG  
Request Rec'd: 05/31/2023  
Approval Date: 05/31/2023 DS  
Permit Expires: 11/30/2023

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: DJ Burke Investments, LLC 139 County Road 350E Teutopolis, IL 62467 Cumberland County Contact: Daniel Burke 217/994-3463	<b>FACILITY</b> - name and address where tanks are located: Wessel's 101 East Main St. Teutopolis, IL 62467 Effingham County Contact: Daniel Burke 217/857-3553
--	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve

**Summary of Work**

Replacing existing single wall spill container with double wall spill container. Also replacing overfill valve and riser pipe from tank to spill container.

**Special Contingencies**

Replacing existing single wall spill container with double wall spill container. Also replacing overfill valve and riser pipe from tank to spill container.

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Pemco Service Company, Inc. 1040 East Second Street Gilman, IL 60938	Contact Person: William "Butch" VonDrehle Phone: 217/822-8628 Email: cmoore52@frontier.com Contractor License # IL1224 Exp. 2/26/2024

Sincerely,



Daniel Starks