



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY	
Facility #:	1020670
Permit #:	00233-2023UPG
Request Rec'd:	03/03/2023
Amended Date:	05/31/2023 DS
Approval Date:	03/04/2023 DS
Permit Expires:	09/06/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Road Ranger, LLC 1501 Woodfield Rd., Suite 300 S Schaumburg, IL 60173 Cook County Contact: John Carabelli 815/387-1700	FACILITY - name and address where tanks are located: Road Ranger #263 3041 N. Illinois Rt. 71 Ottawa, IL 61350 LaSalle County Contact: Kim Phalen 815/387-1700
--	---

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
13	Diesel Fuel	20,000	Currently in use	Federal
14	Diesel Fuel	20,000	Currently in use	Federal

Tank 13 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Double Wall Ameron Dualoy 3000/LCX	Replacing - Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX

Tank 14 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Double Wall Ameron Dualoy 3000/LCX	Replacing - Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX

Summary of Work Files

See summary of work files attached to the permit application.

Summary of Work

5. Install new bulkhead fittings, run a new 2" LCX line and re-connect to the 90's at the bottom of the existing flex hoses.
6. With the ILOFSM on site air test the satellite line and water test both sumps.
7. Backfill, pin to the existing concrete and re-pour.
8. Have a 3rd party line test performed on this satellite line.
9. Re-install the master and satellite dispensers. Make electrical and product piping connections.

Special Contingencies

Amendment Reason:

we are repairing 3 feet of pipe as found leak right at sump wall and don't need removal permit as just making repairs to this pipe now. we are repairing 3 feet of pipe as found leak right at sump wall and don't need removal permit as just making repairs to this pipe now.

PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc.
5060 Arsenal Street
St. Louis, MO 63139

Contact Person: Jimmy Spiros
Phone: 314/226-7112
Email: jimmy_spiros@neumayerequipment.com
Contractor License # IL1502 Exp. 3/26/2024

Sincerely,



Daniel Starks