



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2027396
Permit #: 00581-2023UPG
Request Rec'd: 05/31/2023
Approval Date: 05/31/2023 DS
Permit Expires: 11/30/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Sysco Food Service 250 Wieboldt Dr Des Plaines, IL 60016 Contact: Victor Arciga 708/699-5400	FACILITY - name and address where tanks are located: Sysco Food Service 250 Wieboldt Dr Des Plaines, IL 60016 Cook County Contact: Victor Arciga 708/699-5455
---	--

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	20,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Double Wall Ameron Dualoy 3000/L	Replacing - Piping - Fiberglass Double Wall A.O. Smith

Summary of Work

Replacing existing double walled fiberglass pipe from just outside of pump sump to just outside of dispenser sump and tied into the existing double walled pipe.

Special Contingencies

Replacing existing double walled fiberglass pipe from just outside of pump sump to just outside of dispenser sump and tied into the existing double walled pipe.
Replaced piping exceeds 20 feet or 50% of the total pipe run.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: 708/474-3344 Email: ed@bkequip.com Contractor License # IL1207 Exp. 2/14/2024

Sincerely,

Daniel Starks