



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 4032918
Permit #: 00583-2023UPG
Request Rec'd: 06/01/2023
Approval Date: 06/01/2023 DS
Permit Expires: 12/01/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Eastern Illinois University Facilities Planning and Mgmt Charleston, IL 61920 Coles County Contact: John Sigler 217/581-6209	FACILITY - name and address where tanks are located: Central Stores University Dr & Hayes Ave Charleston, IL 61920 Coles County Contact: Kevin Hardwick 217/581-2119
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Used Oil	600	Currently in use	Federal

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

Replacing single wall spill container on tank 4 with double wall spill container. Replacing riser pipe from tank to spill container.

Special Contingencies

Replacing single wall spill container on tank 4 with double wall spill container. Replacing riser pipe from tank to spill container.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Pemco Service Company, Inc. 1040 East Second Street Gilman, IL 60938	Contact Person: William "Butch" VonDrehle Phone: 217/822-8628 Email: cmoore52@frontier.com Contractor License # IL1224 Exp. 2/26/2024

Sincerely,

Daniel Starks