



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2002969
Permit #: 00588-2023ABN
Request Rec'd: 06/01/2023
Approval Date: 06/04/2023 DS
Permit Expires: 12/05/2023

**Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. The tank owner must submit an amended Notification for Underground Storage Tanks form within 30 days after the abandonment-in-place at: <https://webapps.sfm.illinois.gov/USTPortal/NotificationForm>

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Hentzen Coatings, Inc. 6937 W. Mill Road Milwaukee, WI 532181225 (None) County Contact: George Curry 414/353-4200	FACILITY - name and address where tanks are located: Hentzen Coatings, Inc. 1500 Lathem Street Batavia, IL 60510 Kane County Contact: Charlie See 630/761-4326
---	---

Tanks on the Permit

Tank #	Capacity	Product	Fill Material	Comments
15	6,000	Hazardous Substance	Inert material mixed with portland cement	
16	6,000	Isophorone	Inert material mixed with portland cement	
17	6,000	Hazardous Substance	Inert material mixed with portland cement	
18	6,000	Toluene	Inert material mixed with portland cement	

Location of tanks being abandoned

these tanks are located adjacent to tanks that are remaining, and have a large overhead piping rack running over them.

Location of piping being abandoned

No mention of piping being abandoned in permit application

Explanation of Waiver Document

See Explanation of Waiver document attached to the permit application.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 630/878-6354 Email: jasonre@rstenstrom.com Contractor License # IL1890 Exp. 3/7/2024

Sincerely,

Daniel Starks