



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY
Facility #: 6036473
Permit #: 00594-2023UPG
Request Rec'd: 06/06/2023
Amended Date: 06/06/2023 DS
Approval Date: 06/06/2023 DS
Permit Expires: 12/06/2023

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

<p>OWNER OF TANKS - Corporation, partnership, or other business entity: Casey's Retail Company 3305 SE Delaware Ave. P.O. Box 3004 Ankeny, IA 50021 Contact: Lee Lytle 515/446-6231</p>	<p>FACILITY - name and address where tanks are located: Casey's General Store #2047 3499 Fosterburg Road Alton, IL 62002 Madison County Contact: Jill Reams-Widder 515/965-6238</p>
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
2	B-11	10,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	New
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve

Summary of Work Files

See summary of work files attached to the permit application.

Summary of Work

install a new DW spill bucket, poppit drop tube, fill adaptor and cap on nolead

INstalled new DW spill and drop tube on Tank #2 instead of Tank #1

Special Contingencies

Amendment Reason:

AMending this to Tank #2

PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>Neumayer Equipment Company, Inc. 5060 Arsenal Street St. Louis, MO 63139</p>	<p>Contact Person: Jimmy Spiros Phone: 314/772-4618 Email: HEATHER_HINDS@NEUMAYEREQUIPMENT.COM Contractor License # IL1502 Exp. 3/26/2024</p>

Sincerely,

Daniel G. Starks

Daniel Starks