



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY
Facility #: 2009039
Permit #: 00554-2023UPG
Request Rec'd: 05/22/2023
Amended Date: 06/06/2023 DS
Approval Date: 05/22/2023 SB
Permit Expires: 11/22/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: 810 Roselle Real Estate, Inc. 810 N. Roselle Rd. Hoffman Estates, IL 60169 (None) County Contact: James Johnson 847/845-5596	FACILITY - name and address where tanks are located: Mobil 810 N. Roselle Rd. Hoffman Estates, IL 60172 Cook County Contact: Sunil Shah 708/519-9250
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Gasoline - Regular	10,000	Currently in use	Federal

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve OPW 53VML
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

Break out existing single wall spill bucket and replace same with double wall bucket. Replace ball float on same tank with overfill drop tube

Special Contingencies

Amendment Reason:

Include overfill drop tube replacement on permit

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Superior Petroleum Marketers, Inc. 2336 Albright Lane P. O.Box 4648 Wheaton, IL 601894648	Contact Person: Steve Tuttle Phone: 630/588-1198 Email: tuttle.steve11@gmail.com Contractor License # IL2087 Exp. 2/4/2024

Sincerely,

Shelly Bradley