



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2001509
Permit #: 00602-2023ABN
Request Rec'd: 06/06/2023
Approval Date: 06/06/2023 DS
Permit Expires: 12/06/2023

**Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. The tank owner must submit an amended Notification for Underground Storage Tanks form within 30 days after the abandonment-in-place at: <https://webapps.sfm.illinois.gov/USTPortal/NotificationForm>

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: SFG ISF Melrose Park Armitage, LLC 3280 Peachtree Rd NE, Suite 2770 Atlanta, GA 30305 Fulton County Contact: Patrick Heffernan 770/630-8399	FACILITY - name and address where tanks are located: MDM Express 2090 North Mannheim Road Melrose Park, IL 60160 Cook County Contact: Nikolay Vasilev 770/630-8399
---	---

Tanks on the Permit For Piping Only

Tank #	Capacity	Product	Fill Material	Comments
4	12,000	Used Oil	Piping Capped Off	Piping runs from tank, which is being removed to inside the building either through or under foundation wall

Location of piping being abandoned

Inspector onsite today to oversee removal. Piping runs from tank, which is being removed to inside the building either through or under foundation wall

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
RW Collins Company 7225 West 66th Street Chicago, IL 60638	Contact Person: Lisa Kruse Phone: 708/308-8217 Email: ademauro@rwcollins.com Contractor License # IL772 Exp. 2/9/2024

Sincerely,

Daniel Starks