



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2022452
Permit #: 00607-2023UPG
Request Rec'd: 06/07/2023
Approval Date: 06/07/2023 DS
Permit Expires: 12/07/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Heidner Property Management 5277 Trillium Blvd. Hoffman Estates, IL 60192 Cook County Contact: Rick Heidner 630/894-0099	FACILITY - name and address where tanks are located: Marathon Food Mart & Gas 9300 South Cicero Oak Lawn, IL 60453 Cook County Contact: Rafique Khan 708/424-8740
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Gasoline - Regular	10,000	Currently in use	Federal
6	Gasoline - Premium	10,000	Currently in use	Federal
7	Diesel Fuel	10,000	Currently in use	Federal

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Other Non-vented check valve	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Other Non-vented check valve	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Other Non-vented check valve	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection

Summary of Work

Removing the WPLLD leak detectors and install mechanical leak detectors

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Stenstrom Petroleum Services Group
2422 Center Street
Rockford, IL 61108

Contact Person: Robert Stenstrom
Phone: 708/485-4105
Email: nickb@rstenstrom.com
Contractor License # IL1890 Exp. 4/12/2024

Sincerely,



Daniel Starks